

- 2" Top mount control valve suited for commercial/industrial applications
- Lead free brass construction
- Economical stainless steel optional meter assembly
- Service flow rate of 115 gpm, backwash 80 gpm
- Solid state microprocessor with easy access front panel settings
- Front panel display for time of day, days until next regeneration, volume remaining, current flow rate and total volume used (Totalizer)
- Four methods to initiate regeneration; meter immediate, meter delayed, time clock delayed or pressure differential
- Optional double backwash feature offers optimum regeneration, cleaning ability and efficiency
- Fully adjustable cycle times with 6-cycle control delivers controlled backwash, downflow brining/slow rinse, second backwash, fast rinse, refill and downflow service
- Coin Cell Lithium battery back-up with an 8 hour carry over
- 12-volt output AC Adapter provides safe and easy installation
- Post treated water regenerant refill
- Reliable and proven DC drive

Water Specialist 2" EE Control Specifications

<u> </u>	•
Inlet/Outlet (1)	2" Female NPT
Cycles	
Valve Material	
Regeneration	
CONTROL VALVE FLOW RATES	
Service @15 psi drop (includes meter)	115 gpm
Backwash @ 25 psi drop	80 gpm
Cv Service	29.7
Cv Backwash	16.0
OPERATING PRESSURES	
Minimum/Maximum	20 psi – 125 psi
OPERATING TEMPERATURES	
Minimum/Maximum	400 1100 E
WIIIIIIIIIII/Waxiiiiuiii	40 - 110 F
METER SPECIFICATIONS	
Accuracy	± 5%
Flow Rate Range	
Gallon Range	
Totalizer	
	c,ccc,ccc ganene
DIMENSIONS & WEIGHT	
Distributor Pilot	
Valve bodies with 2" Female NPT Inlet & Outlet	1.90" OD (1.5" NPS)
Drain Line Connection	
Brine Line Adapters Included	
	3/4" x 1" solvent weld elbow and
	½" OD Poly Tube Compression
Mounting Base	
Height From Top Of Tank	
Shipping Weight With Meter	
Shipping weight with Meter	29 103.
ELECTRICAL SPECIFICATIONS	AC Adapter
Supply Voltage	-
Supply Frequency	
Output Voltage	
Output Current	
ou.put out out out out out out out out out o	
TANK APPLICATIONS	
Water Softener	12" - 48" diameter
Water Filter (2)	12" - 36" diameter
CYCLES OF OPERATION	
	<u>Softener</u> <u>Filter</u>
Cycle	Range of time in minutes
4 = 1 1 4 4 / 61 \	
1. Backwash 1st (upflow)	
2. Regenerate Draw/Slow Rinse (downflow)	
2. Regenerate Draw/Slow Rinse (downflow)	1-20 Rinse 1-95
Regenerate Draw/Slow Rinse (downflow) Backwash 2 nd (upflow)	1-20 Rinse 1-95 1-95

Options: Backwash Filter, Weather Cover

Compatible with the following typical concentrations of regenerants or chemicals: Sodium chloride, potassium chloride, potassium permanganate, sodium bisulfite, chlorine and chloramines

^{1.} See Distributor Pilot

^{2.} Filter tank size calculated @ 10 gpm of backwash per square foot of bed area